



Legislation Details (With Text)

File #: RLH FCO 11- 51 **Version:** 2
Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed
In control: City Council
Final action: 6/1/2011
Title: Appeal of Ronald Christenson to a Fire Inspection Correction Notice at 1406 HAZEL STREET NORTH.
Sponsors: Dan Bostrom
Indexes: Fire C of O Letter, Ward - 6
Code sections:
Attachments: 1. 1406 Hazel.appeal.4-15-11.pdf

Date	Ver.	Action By	Action	Result
6/6/2011	2	Mayor's Office	Signed	
6/1/2011	2	City Council	Adopted	Pass
5/3/2011	1	Legislative Hearings	Referred	

Appeal of Ronald Christenson to a Fire Inspection Correction Notice at 1406 HAZEL STREET NORTH.

Item #6 of reference #112917 "Provide and maintain habitable area with ceiling height of 7 ft over 1/2 floor area." Existing height is sufficiently high for a 6' individual to walk around comfortably without ducking; however, the single bedroom/bath with egress window has a dropped finished ceiling and is only 6 1/2 ft of headroom. It is not uncomfortable to appellant but might be to people over 6' tall. Removal of the ceiling would still not conform and cement floor makes lowering impractical.

April 5, 2011

WHEREAS, in the matter of the appeal of Ronald Christenson to a Fire Inspection Correction Notice at 1406 HAZEL STREET NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress bedroom window in the attic; grant a 2-inch variance on the openable height of the egress window in the main floor bedroom, grant the appeal on the driveway; deny the appeal on the ceiling height in the basement and can not use the room as a bedroom or habitable space; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.