



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
21

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 6/1/2011

Title: Appeal of Carol Beck to a Fire Certificate of Occupancy Correction Notice at 1640 and 1642 MCAFEE STREET.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1640-42 McAfee.appeal.4-26-11.pdf, 2. 1640-1642 McAfee St.Beck Ltr 5-3-11.pdf

Date	Ver.	Action By	Action	Result
6/6/2011	2	Mayor's Office	Signed	
6/1/2011	2	City Council	Adopted	Pass
5/3/2011	1	Legislative Hearings	Referred	

Appeal of Carol Beck to a Fire Certificate of Occupancy Correction Notice at 1640 and 1642 MCAFEE STREET.

Egress windows

April 19, 2011

Yes, 5-inch variance in height.

No hearing necessary.

WHEREAS, in the matter of the appeal of Carol Beck to a Fire Certificate of Occupancy Correction Notice at 1640 and 1642 McAfee Street, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in all bedrooms for 1640 and in both bedrooms for 1642; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.