



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
18

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 6/1/2011

**Title:** Appeal of Rita Tierney, 33rd Company, to a Fire Inspection Correction Notice at 2116 SCHEFFER AVENUE.

**Sponsors:** Pat Harris

**Indexes:** Fire C of O Letter, Ward - 3, Windows

**Code sections:**

**Attachments:** 1. 2116 Scheffer.appeal.4-13-11.pdf, 2. 2116 Scheffer Ave.33rd Co Ltr 5-3-11.pdf

Date	Ver.	Action By	Action	Result
6/6/2011	2	Mayor's Office	Signed	
6/1/2011	2	City Council	Adopted	Pass
5/3/2011	1	Legislative Hearings	Referred	

Appeal of Rita Tierney, 33rd Company, to a Fire Inspection Correction Notice at 2116 SCHEFFER AVENUE.

Applying for variance for 2nd floor windows. The window sizes are as follows:

East - 18.25 h X 38 w, glazed 8.6 sq. ft.

West - 18.5 h X 38 w, glazed 8.6 sq. ft.

(See attached inspection report)

April 5, 2011

No hearing necessary. Recommend variance on egress window dimensions.

WHEREAS, in the matter of the appeal of Rita Tierney, 33rd Company, to a Fire Inspection Correction Notice at 2116 SCHEFFER AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5.7-inch variance on the openable height of the egress windows in the second floor east and west bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.