



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH WP 11- 22 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 6/15/2011
Title: Appeal of Roxberg Rehab to an Egress Window Non-Compliance Determination at 81 GEORGE STREET WEST.
Sponsors: Dave Thune
Indexes: Ward - 2, Windows
Code sections:
Attachments: 1. 81 George E.appeal.5-23-11.pdf, 2. 81 George St. W.Roxberg Ltr 5-24-11.pdf

Date	Ver.	Action By	Action	Result
6/20/2011	2	Mayor's Office	Signed	
6/15/2011	2	City Council	Adopted	Pass
5/24/2011	1	Legislative Hearings	Referred	

Appeal of Roxberg Rehab to an Egress Window Non-Compliance Determination at 81 GEORGE STREET WEST.

(Nothing noted)

May 20, 2011

WHEREAS, in the matter of Appeal of Roxberg Rehab to an Egress Window Non-Compliance Determination at 81 GEORGE STREET WEST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends granting a variance for the one double hung window measuring 16 inches wide by 34 inches high on the condition that the room is not being used as a sleeping room; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.