



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
61

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 7/6/2011

Title: Appeal of Joe Skelly to a Fire Certificate of Occupancy Correction Notice at 1231 KENNARD STREET.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1231 Kennard.appeal.6-7-11.pdf, 2. 1231 Kennard St.Skelly Ltr 6-7-11.pdf

Date	Ver.	Action By	Action	Result
7/12/2011	2	Mayor's Office	Signed	
7/6/2011	2	City Council	Adopted	Pass
6/7/2011	1	Legislative Hearings	Referred	

Appeal of Joe Skelly to a Fire Certificate of Occupancy Correction Notice at 1231 KENNARD STREET.

5. Original windows: 1" deficient in height but exceeds code for width.

May 11, 2011

Yes, 1 inch in the openable height.

No hearing necessary.

WHEREAS, in the matter of the Appeal of Joe Skelly to a Fire Certificate of Occupancy Correction Notice at 1231 KENNARD STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable height of the egress windows in the upstairs and downstairs bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.