



## Legislation Details (With Text)

**File #:** RLH WP 11- 23 **Version:** 2  
**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 7/6/2011  
**Title:** Appeal of Sam Riesgraf, on behalf of SMR Real Estate, to an Egress Window Non-Compliance Determination at 995 BURGESS STREET.  
**Sponsors:** Melvin Carter III  
**Indexes:** Ward - 1, Windows  
**Code sections:**  
**Attachments:** 1. 995 Burgess.appeal.5-20-11.pdf, 2. 995 Burgess Ltr 6-7-11.pdf

Date	Ver.	Action By	Action	Result
7/11/2011	2	Mayor's Office	Signed	
7/6/2011	2	City Council	Adopted	Pass
6/7/2011	1	Legislative Hearings	Referred	

Appeal of Sam Riesgraf, on behalf of SMR Real Estate, to an Egress Window Non-Compliance Determination at 995 BURGESS STREET.

(2 Windows)

May 26, 2011

Yes, 6.5 inch variance in height of egress window opening.

No hearing necessary.

WHEREAS, in the matter of the appeal of Sam Riesgraf, on behalf of SMR Real Estate, to an Egress Window Non-Compliance Determination at 995 BURGESS STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6.5-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 17.5 inches high by 34.5 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.