



## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
75

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 7/6/2011

**Title:** Appeal of Matt Schumacher to a Fire Certificate of Occupancy Correction Notice at 1088 SUMMIT AVENUE.

**Sponsors:** Dave Thune

**Indexes:** Fire C of O Letter, Ward - 2, Windows

**Code sections:**

**Attachments:** 1. 1088 Summit.appeal.6-15-11.pdf

Date	Ver.	Action By	Action	Result
7/12/2011	2	Mayor's Office	Signed	
7/6/2011	2	City Council	Adopted	Pass
6/21/2011	1	Legislative Hearings	Referred	

Appeal of Matt Schumacher to a Fire Certificate of Occupancy Correction Notice at 1088 SUMMIT AVENUE.

Only Egress Windows (see attachment)

June 8, 2011

Yes, 2 inches in egress opening height.

No hearing necessary.

WHEREAS, in the matter of the appeal of Matt Schumacher to a Fire Certificate of Occupancy Correction Notice at 1088 SUMMIT AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1.5-inch variance on the openable height of the egress windows in both units - 3 bedrooms in each unit; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.