



Legislation Details (With Text)

File #: RLH WP 11- 32 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 7/6/2011
Title: Appeal of Window World, on behalf of Hanz Lehrke, to an Egress Window Non-Compliance Determination at 1871 STILLWATER AVENUE.
Sponsors: Dan Bostrom
Indexes: Ward - 6, Windows
Code sections:
Attachments: 1. 1871 Stillwater.appeal.5-31-11.pdf, 2. 1871 Stillwater Ave.Dahl Ltr 6-28-11.pdf

Date	Ver.	Action By	Action	Result
7/11/2011	2	Mayor's Office	Signed	
7/6/2011	2	City Council	Adopted	Pass
6/28/2011	1	Legislative Hearings	Referred	

Appeal of Window World, on behalf of Hanz Lehrke, to an Egress Window Non-Compliance Determination at 1871 STILLWATER AVENUE.

Asking for variance on windows

June 16, 2011

Yes, 6.6 inches in the egress opening height. No hearing necessary.

WHEREAS, in the matter of the appeal of Window World, on behalf of Hanz Lehrke, to an Egress Window Non-Compliance Determination at 1871 STILLWATER AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends granting a 6.5-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 17.5 inches high by 25.5 inches wide, Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.