



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
62

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 7/6/2011

Title: Appeal of Scott McCoy to a Fire Certificate of Occupancy Correction Notice at 1071 FOREST STREET.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1071 Forest.appeal.5-20-11.pdf, 2. 1071 Forest St.Mccoy Ltr 6-7-11.pdf

Date	Ver.	Action By	Action	Result
7/12/2011	2	Mayor's Office	Signed	
7/6/2011	2	City Council	Adopted As Amended	Pass
7/5/2011	2	Legislative Hearings	Referred	
6/28/2011	2	Legislative Hearings	Referred	
6/14/2011	1	Legislative Hearings	Referred	
6/7/2011	1	Legislative Hearings	Laid Over	

Appeal of Scott McCoy to a Fire Certificate of Occupancy Correction Notice at 1071 FOREST STREET.

Only Egress Windows

May 18, 2011

Yes, for units 101, 102 and 103, 8 inches in height of egress opening.

Yes, for units 202, 203 and 204, 5 inches in height of egress opening.

No, for unit 201 where egress opening height was measured at 11.5 inches.

Only on Unit 201.

AMENDED 7/6/2011

WHEREAS, in the matter of the appeal of Scott McCoy to a Fire Certificate of Occupancy Correction Notice at 1071 FOREST STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer's recommendation is to grant variances of 8 inches in height of egress opening for units 101, 102 and 103; and grant variance of 5 inches in height of egress opening height for units 201, 202, 203 and 204; ~~and the balance of the recommendations for this appeal are forthcoming;~~
Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's

recommendation in this matter.