



## Legislation Details (With Text)

**File #:** RLH WP 11- 42 **Version:** 2

**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 8/3/2011

**Title:** Appeal of The Home Depot At-Home Services, on behalf of Thomas Lloyd, to an Egress Window Non-Compliance Determination at 264 WYOMING STREET EAST.

**Sponsors:** Dave Thune

**Indexes:** Ward - 2, Windows

**Code sections:**

**Attachments:** 1. 264 Wyoming.appeal.6-28-11.pdf

Date	Ver.	Action By	Action	Result
8/12/2011	2	Mayor's Office	Signed	
8/3/2011	2	City Council	Adopted	Pass
7/5/2011	1	Legislative Hearings	Referred	

Appeal of The Home Depot At-Home Services, on behalf of Thomas Lloyd, to an Egress Window Non-Compliance Determination at 264 WYOMING STREET EAST.

Only Egress Windows

June 28, 2011

2 double hung replacement measuring 20 inches high by 19 inches wide. Yes, grant 1 inch variance in the opening width and 4 inches in the opening height of the egress opening, No hearing necessary.  
Hearing on the the three double hung replacement measuring 10.5 inches high by 15.5 inches wide.

WHEREAS, in the matter of The Home Depot At-Home Services, on behalf of Thomas Lloyd, to an Egress Window Non-Compliance Determination at 264 WYOMING STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height and a 1-inch variance on the openable width of two double hung replacement egress bedroom windows measuring 20 inches high by 19 inches wide, and deny the three double hung replacement egress bedroom windows measuring 10.5 inches high by 15.5 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.