



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
84

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 8/3/2011

Title: Appeal of Randy J. Anderson to a Fire Certificate of Occupancy Inspection Correction Notice at 866 ARKWRIGHT STREET.

Sponsors: Lee Helgen

Indexes: Fire C of O Letter, Ward - 5, Windows

Code sections:

Attachments: 1. 866 Arkwright.appeal.6-22-11.pdf, 2. 866 Arkwright St.Anderson Ltr 7-12-11.pdf, 3. 866 Arkwright St.Anderson Ltr 7-15-11.pdf

Date	Ver.	Action By	Action	Result
8/12/2011	2	Mayor's Office	Signed	
8/3/2011	2	City Council	Adopted	Pass
7/12/2011	1	Legislative Hearings	Referred	

Appeal of Randy J. Anderson to a Fire Certificate of Occupancy Inspection Correction Notice at 866 ARKWRIGHT STREET.

Windows seem to work fine and a person could get out in case of emergency if opened properly.

May 11, 2011

Yes, 2 inches in openable height of egress window in downstairs east bedroom; 6 inches in openable height of egress window in downstairs west bedroom.

No hearing necessary.

WHEREAS, in the matter of Appeal of Randy J. Anderson to a Fire Certificate of Occupancy Inspection Correction Notice at 866 ARKWRIGHT STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the downstairs east bedroom and a 6-inch variance on the openable height of the egress window in the downstairs west bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.