



Legislation Details (With Text)

File #: RLH WP 11- 40 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 8/3/2011

Title: Appeal of Bryan Horton, Renewal by Andersen, on behalf of Eva Smith, to an Egress Window Non-Compliance Determination at 1830 MECHANIC AVENUE.

Sponsors: Dan Bostrom

Indexes: Ward - 6, Windows

Code sections:

Attachments: 1. 1830 Mechanic.appeal.6-27-11.pdf, 2. 1830 Mechanic Ave.Andersen Windows PC ltr 7-12-11.pdf

Date	Ver.	Action By	Action	Result
8/12/2011	2	Mayor's Office	Signed	
8/3/2011	2	City Council	Adopted	Pass
7/12/2011	1	Legislative Hearings	Referred	

Appeal of Bryan Horton, Renewal by Andersen, on behalf of Eva Smith, to an Egress Window Non-Compliance Determination at 1830 MECHANIC AVENUE.

We are appealing 7 replacement windows that will not comply w/egress policy. Window openings will be short in height by 6". Opening width and overall glazed area will be exceeded. Please approve.

June 24, 2011

Yes, 6 inches in the opening height of the egress opening.

WHEREAS, in the matter of the Appeal of Renewal by Andersen, on behalf of Eva Smith, to an Egress Window Non-Compliance Determination at 1830 MECHANIC AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6-inch variance on the openable height of seven double hung replacement egress bedroom windows measuring 18 inches high by 36 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.