



## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
101

**Type:** Resolution LH Fire Ordered **Status:** Passed  
Windows

**In control:** City Council

**Final action:** 9/7/2011

**Title:** Appeal of Karen Hupp to an Egress Window Non-Compliance Determination at 873 JENKS AVENUE.

**Sponsors:** Dan Bostrom

**Indexes:** Appeal, Ward - 6

**Code sections:**

**Attachments:** 1. 873 Jenks.appeal.7-11-11.pdf, 2. 873 Jenks Ave.Hupp PC ltr 8-2-11.pdf

Date	Ver.	Action By	Action	Result
9/9/2011	2	Mayor's Office	Signed	
9/7/2011	2	City Council	Adopted	Pass
8/2/2011	1	Legislative Hearings	Referred	

Appeal of Karen Hupp to an Egress Window Non-Compliance Determination at 873 JENKS AVENUE.

The windows are good operating replacement windows that were in the house when we purchased it.

June 29, 2011

Yes, 2 inches in openable height. No hearing necessary.

WHEREAS, in the matter of the appeal of Karen Hupp to an Egress Window Non-Compliance Determination at 873 JENKS AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress windows in all three bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.