



Legislation Details (With Text)

File #: RLH FCO 11- **Version:** 2
264

Type: Resolution LH Fire C of O OR **Status:** Passed
Correction Order

In control: City Council

Final action: 9/7/2011

Title: Appeal of Joseph Uebel to a Fire Certificate of Occupancy Correction Notice at 1898-1900 FORD PARKWAY.

Sponsors: Pat Harris

Indexes: Fire C of O Letter, Ward - 3

Code sections:

Attachments: 1. 1898-1900 Ford.appeal.7-25-11.pdf, 2. 1898-1900 Ford Pkwy.Uebel Ltr 8-2-11.pdf

| Date | Ver. | Action By | Action | Result |
|----------|------|----------------------|----------|--------|
| 9/9/2011 | 2 | Mayor's Office | Signed | |
| 9/7/2011 | 2 | City Council | Adopted | Pass |
| 8/2/2011 | 1 | Legislative Hearings | Referred | |

Appeal of Joseph Uebel to a Fire Certificate of Occupancy Correction Notice at 1898-1900 FORD PARKWAY.

Window size 1 inch short.

July 20, 2011

Yes, 1 inch in height of egress opening.

WHEREAS, in the matter of the appeal of Joseph Uebel to a Fire Certificate of Occupancy Correction Notice at 1898-1900 FORD PARKWAY, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable height of the egress bedroom windows in all four bedrooms measuring 23 inches high by 33 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.