



Legislation Details (With Text)

File #: RLH WP 11- 51 **Version:** 2

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 9/7/2011

Title: Appeal of Sheila Moore for Capital Siding Windows and Construction, on behalf of Robert and Mary Kuhl, to an Egress Window Non-Compliance Determination at 1804 HIGHLAND PARKWAY.

Sponsors: Pat Harris

Indexes: Ward - 3, Windows

Code sections:

Attachments: 1. 1804 Highland.appeal.7-25-11.pdf

Date	Ver.	Action By	Action	Result
9/9/2011	2	Mayor's Office	Signed	
9/7/2011	2	City Council	Adopted	Pass
8/9/2011	1	Legislative Hearings	Referred	

Appeal of Sheila Moore for Capital Siding Windows and Construction, on behalf of Robert and Mary Kuhl, to an Egress Window Non-Compliance Determination at 1804 HIGHLAND PARKWAY.

Nothing indicated.

July 21, 2011

Yes, 5 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Sheila Moore for Capital Siding Windows and Construction, on behalf of Robert and Mary Kuhl, to an Egress Window Non-Compliance Determination at 1804 HIGHLAND PARKWAY, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends tha the City Council grant a 5-inch variance on the openable height of two (2) double-hung replacement egress bedroom windows measuring 19.93 inches high by 26.375 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.