



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
118

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 9/7/2011

Title: Appeal of Wendy Teeters to a Notice of Condemnation as Unfit for Human Habitation and Order to Vacate at 1843 STILLWATER AVENUE.

Sponsors: Dan Bostrom

Indexes: Vacate Order, Ward - 6, Windows

Code sections:

Attachments: 1. 1843 Stillwater.appeal.8-2-11.pdf

Date	Ver.	Action By	Action	Result
9/9/2011	2	Mayor's Office	Signed	
9/7/2011	2	City Council	Adopted	Pass
8/9/2011	1	Legislative Hearings	Referred	

Appeal of Wendy Teeters to a Notice of Condemnation as Unfit for Human Habitation and Order to Vacate at 1843 STILLWATER AVENUE.

Installed 4 new double-hung windows but are a few inches short. Contractor measured window height, not "openable" area - width is good.

July 28, 2011

Yes, 5 inches in opening height of egress window opening.

WHEREAS, in the matter of the Appeal of Wendy Teeters to a Notice of Condemnation as Unfit for Human Habitation and Order to Vacate at 1843 STILLWATER AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the double-hung windows in the bedrooms measuring 19 inches openable height and 29 inches openable width; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.