



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Details (With Text)

**File #:** RLH FCO 11- 288 **Version:** 2  
**Type:** Resolution LH Fire C of O OR Correction Order **Status:** Passed  
**In control:** City Council  
**Final action:** 9/7/2011  
**Title:** Appeal of Conrad Preiner to a Fire Certificate of Occupancy Correction Notice at 1210 MAGNOLIA AVENUE EAST.  
**Sponsors:** Dan Bostrom  
**Indexes:** Fire C of O Letter, Ward - 6  
**Code sections:**  
**Attachments:** 1. 1210 Magnolia.appeal.8-9-11.pdf

Date	Ver.	Action By	Action	Result
9/9/2011	2	Mayor's Office	Signed	
9/7/2011	2	City Council	Adopted	Pass
8/9/2011	1	Legislative Hearings	Referred	

Appeal of Conrad Preiner to a Fire Certificate of Occupancy Correction Notice at 1210 MAGNOLIA AVENUE EAST.

See pictures and documentation

July 26, 2011

Yes, 4 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Conrad Preiner to a Fire Certificate of Occupancy Correction Notice at 1210 MAGNOLIA AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the windows in each bedroom measuring 20.5 inches openable height X 23.5 inches openable width; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.