



Legislation Details (With Text)

File #: RLH FCO 11- 258 **Version:** 2
Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed
In control: City Council
Final action: 9/7/2011
Title: Appeal of Tony Fares to a Correction Order at 805 ROBERT STREET.
Sponsors: Dave Thune
Indexes: Correction Order, Ward - 2
Code sections:
Attachments: 1. 805 Robert.appeal.7-18-11.pdf

Date	Ver.	Action By	Action	Result
9/9/2011	2	Mayor's Office	Signed	
9/7/2011	2	City Council	Adopted	Pass
8/16/2011	1	Legislative Hearings	Referred	
8/9/2011	1	Legislative Hearings	Referred	

Appeal of Tony Fares to a Correction Order at 805 ROBERT STREET.

Windows are 20.5 H x 24 W;they are new. I just purchased the house. If rotated they provide 24x20. Glazed area is greater than 5 sq. ft, (22"x45").

July 14, 2011

Yes, 4 inches egress opening height.

WHEREAS, in the matter of the appeal of Tony Fares to a Correction Order at 805 ROBERT STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3.5-inch variance on the openable height of both the double hung north and the west windows in the northwest sleeping room; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.