



## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
100

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 9/7/2011

**Title:** Appeal of Tia Yang and Lee Yang to a Fire Certificate of Occupancy Inspection Correction Notice at 929 WILSON AVENUE.

**Sponsors:** Kathy Lantry

**Indexes:** Fire C of O Letter, Ward - 7, Windows

**Code sections:**

**Attachments:** 1. 929 Wilson.appeal.7-8-11.pdf, 2. 929 Wilson Ave.Yang Ltr 8-4-11.pdf

Date	Ver.	Action By	Action	Result
9/9/2011	2	Mayor's Office	Signed	
9/7/2011	2	City Council	Adopted	Pass
8/2/2011	1	Legislative Hearings	Referred	

Appeal of Tia Yang and Lee Yang to a Fire Certificate of Occupancy Inspection Correction Notice at 929 WILSON AVENUE.

Double-hung window 1st floor bedroom openable 17.5 inches Ht. X 31.5 Width and Double-hung window 2nd floor bedroom openable 21" Ht. X 27" Width.

July 1, 2011

Yes, 7 inches in the egress opening height of the 1st floor bedroom and 3 inches in the height of the 2nd floor bedroom.

No hearing necessary.

WHEREAS, in the matter of Tia Yang and Lee Yang to a Fire Certificate of Occupancy Inspection Correction Notice at 929 Wilson Avenue; and

WHEREAS, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 6.5-inch variance on the openable height of the egress window in the first floor bedroom and grant a 3-inch variance on the openable height of the egress window in the second floor bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.