

City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FOW 11- Version: 2

113

Type: Resolution LH Fire Ordered

Windows

Status: Passed

In control: City Council

Final action: 9/7/2011

Title: Appeal of Michael Taff to a Fire Certificate of Occupancy Correction Notice at 1381 HAZELWOOD

STREET.

Sponsors: Dan Bostrom

Indexes: Ward - 6, Windows

Code sections:

Attachments: 1. 1381 Hazelwood.appeal.7-25-11.pdf, 2. 1381 Hazelwood-Photos.appeal.8-4-11.pdf

Date	Ver.	Action By	Action	Result
9/9/2011	2	Mayor's Office	Signed	
9/7/2011	2	City Council	Adopted	Pass
8/16/2011	1	Legislative Hearings	Referred	

Appeal of Michael Taff to a Fire Certificate of Occupancy Correction Notice at 1381 HAZELWOOD STREET.

Home was purchased in 2000; windows were installed. House is stucco and replacing all windows would cause severe financial hardship. Double hung windows have both panes removable. Casement as well.

July 18, 2011

WHEREAS, in the matter of the Appeal of Michael Taff to a Fire Certificate of Occupancy Correction Notice at 1381 HAZELWOOD STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal and grant an extension for 90 days to come into compliance with the downstairs egress bedroom windows, and grant a 2-inch variance on the openable width of the egress windows in the upstairs bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.