



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
116

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 9/7/2011

Title: Appeal of Merric Bilotta to an Egress Window Non-Compliance Determination at 423 WYOMING STREET EAST.

Sponsors:

Indexes: Ward - 2, Windows

Code sections:

Attachments: 1. 423 Wyoming St. E.appeal.7-28-11.pdf

Date	Ver.	Action By	Action	Result
9/9/2011	2	Mayor's Office	Signed	
9/7/2011	2	City Council	Adopted	Pass
8/16/2011	1	Legislative Hearings	Referred	

Appeal of Merric Bilotta to an Egress Window Non-Compliance Determination at 423 WYOMING STREET EAST.

Window variance: the windows meet the approved escape window size; however, the height and width are reversed. Mine is 24W X 22.5H. Requirement is 24h x 20.0 w.

July 19, 2011

Yes, 2 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Merric Bilotta to an Egress Window Non-Compliance Determination at 423 WYOMING STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1.5-inch variance on the openable height of the egress windows in all sleeping rooms for Item 1; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.