



Legislation Details (With Text)

File #: RLH WP 11- 57 **Version:** 3

Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 9/21/2011

Title: Appeal of Christopher Hubbuch to an Egress Window Non-Compliance Determination at 719 CHARLES AVENUE.

Sponsors: Melvin Carter III

Indexes: Ward - 1, Windows

Code sections:

Attachments: 1. 719 Charles.appeal.8-23-11.pdf, 2. 719 Charles.Hubbuch Ltr 8-22-11.pdf

Date	Ver.	Action By	Action	Result
9/26/2011	3	Mayor's Office	Signed	
9/21/2011	3	City Council	Adopted	Pass
8/23/2011	2	Legislative Hearings	Referred	

Appeal of Christopher Hubbuch to an Egress Window Non-Compliance Determination at 719 CHARLES AVENUE.

Request to replace conforming window w/non conf. replacement.

July 19, 2011

Yes, 3 inches in egress opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of Christopher Hubbuch to an Egress Window Non-Compliance Determination at 719 CHARLES AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2.5-inch variance on the openable width of one double-hung egress bedroom window measuring 28 inches openable height and 17.5 inches openable width; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.