

City of Saint Paul

City Hall and Court House 15 West Kellogg Boulevard Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FOW 11- Version: 2

124

Type: Resolution LH Fire Ordered

Windows

Status: Passed

In control: City Council

Final action: 9/21/2011

Title: Appeal of Raymond Simpson to an Egress Window Non-Compliance Determination at 1871

CONWAY STREET.

Sponsors: Kathy Lantry

Indexes: Ward - 7, Windows

Code sections:

Attachments: 1. 1871 Conway.appeal.8-03-11.pdf, 2. 1871 Conway.Simpson Ltr 8-22-11.pdf

Date	Ver.	Action By	Action	Result
9/27/2011	2	Mayor's Office	Signed	
9/21/2011	2	City Council	Adopted	Pass
8/23/2011	1	Legislative Hearings	Referred	

Appeal of Raymond Simpson to an Egress Window Non-Compliance Determination at 1871 CONWAY STREET.

Bedroom window is 6 ft. 2 glazed area. Openable width is 23", height is 22". I am requesting a waiver for this window.

July 29, 2011

Yes, 2 inch variance in egress opening height.

WHEREAS, in the matter of the Appeal of Raymond Simpson to an Egress Window Non-Compliance Determination at 1871 CONWAY STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the window measuring 22 inches openable height and 23 inches openable width; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.