City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Details (With Text)

File #:	RLH FCO 11-312 **Version:** 2		
Type:	Resolution LH Fire C of O OR Correction Order	**Status:**	Passed
		In control:	City Council
		Final action:	10/5/2011
Title:	Appeal of Mark Grondahl to a Fire Certificate of Occupancy Inspection Correction Notice at 1654 MCAFEE STREET.		
Sponsors:	Dan Bostrom		
Indexes:	Fire C of O Letter, Ward - 6, Windows		
Code sections:			
Attachments:	1. 1654-1656 Mcafee.appeal.8-12-11.pdf, 2. 1654 McAfee St.Fire C of O Letter.8-18-11.pdf, 3. 1654-1656 McAfee.Grondahl Ltr 8-29-11.pdf, 4. 1654 Mcafee St.Diagram.9-6-11.pdf, 5. 1654 McAfee St.Photos.pdf		

Date	Ver.	Action By	Action	Result
10/11/2011	2	Mayor's Office	Signed	
10/5/2011	2	City Council	Adopted	Pass
9/6/2011	2	Legislative Hearings		
8/23/2011	1	Legislative Hearings	Laid Over	

Appeal of Mark Grondahl to a Fire Certificate of Occupancy Inspection Correction Notice at 1654 MCAFEE STREET.

(Items 2, 10, 12 - See attached letter)

August 4, 2011

Item 10. 42 inches high by 20 inches wide (in compliance)

Hearing on Items 2 and 12.

WHEREAS, in the matter of the Appeal of Mark Grondahl to a Fire Certificate of Occupancy Inspection Correction Notice at 1654 McAfee Street; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal for Item 2 (clearance around electrical panel); and deny the appeal for Item 12 (extension cords); Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.

powered by Legistar™