



Legislation Details (With Text)

File #: RLH WP 11- 79 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 10/5/2011
Title: Appeal of Kendall Burton to an Egress Window Non-Compliance Determination at 1074 JESSIE STREET.
Sponsors: Lee Helgen
Indexes: Ward - 5, Windows
Code sections:
Attachments: 1. 1074 Jessie.appeal.8-17-11.pdf

Date	Ver.	Action By	Action	Result
10/10/2011	2	Mayor's Office	Signed	
10/5/2011	2	City Council	Adopted	Pass
9/6/2011	1	Legislative Hearings		

Appeal of Kendall Burton to an Egress Window Non-Compliance Determination at 1074 JESSIE STREET.

22-1/2" H x 26-7/8" W window opening

July 15, 2011

Yes, 3 inches in egress opening height.

WHEREAS, in the matter of the Appeal of Kendall Burton to an Egress Window Non-Compliance Determination at 1074 JESSIE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3 inch variance in the egress window opening height for the east bedroom of Unit 2; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.