



## Legislation Details (With Text)

**File #:** RLH WP 11- 58 **Version:** 2  
**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 10/5/2011  
**Title:** Appeal of Bob Sutherland to an Egress Window Non-Compliance Determination at 2091 PRINCETON AVENUE.  
**Sponsors:** Pat Harris  
**Indexes:** Ward - 3, Windows  
**Code sections:**  
**Attachments:** 1. 2091 Princeton.appeal.8-17-11.pdf

Date	Ver.	Action By	Action	Result
10/10/2011	2	Mayor's Office	Signed	
10/5/2011	2	City Council	Adopted	Pass
9/6/2011	1	Legislative Hearings		

Appeal of Bob Sutherland to an Egress Window Non-Compliance Determination at 2091 PRINCETON AVENUE.

Permit to install 1 bedroom window. It is the largest available to match existing but did not make egress code for St. Paul but does comply with MN Building Code.

August 15, 2011

Yes, 7 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the appeal of Bob Sutherland to an Egress Window Non-Compliance Determination at 2091 PRINCETON AVENUE the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 7-inch variance on the openable height of one double hung replacement egress bedroom window measuring 17 13/16 inches high by 23 5/16 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.