



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
133

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 10/5/2011

Title: Appeal of Joan Lawson to a Fire Certificate of Occupancy Inspection Correction Notice at 1883 HOYT AVENUE EAST.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1883 Hoyt.appeal.8-12-11.pdf

Date	Ver.	Action By	Action	Result
10/11/2011	2	Mayor's Office	Signed	
10/5/2011	2	City Council	Adopted	Pass
9/6/2011	1	Legislative Hearings		

Appeal of Joan Lawson to a Fire Certificate of Occupancy Inspection Correction Notice at 1883 HOYT AVENUE EAST.

I am asking for a variance on the egress window. The difference is only an inch.

August 5, 2011

Yes, 1 inch in egress opening height.

No hearing necessary.

WHEREAS, in the matter of the Appeal of Joan Lawson to a Fire Certificate of Occupancy Inspection Correction Notice at 1883 HOYT AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance for the egress window opening for the south east side bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.