



Legislation Details (With Text)

File #: RLH WP 11- 78 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 10/5/2011
Title: Appeal of Mai Vang to an Egress Window Non-Compliance Determination at 1491 DIETER STREET.
Sponsors: Dan Bostrom
Indexes: Ward - 6, Windows
Code sections:
Attachments: 1. 1491 Dieter.appeal.8-22-11.pdf

Date	Ver.	Action By	Action	Result
10/10/2011	2	Mayor's Office	Signed	
10/5/2011	2	City Council	Adopted	Pass
9/6/2011	1	Legislative Hearings		

Appeal of Mai Vang to an Egress Window Non-Compliance Determination at 1491 DIETER STREET.

Egress windows

August 22, 2011

Yes, 7 and 6 inches in egress opening height of windows, and 2 inch variance on sill height requirement. No hearing necessary.

WHEREAS, in the matter of the appeal of Mai Vang to an Egress Window Non-Compliance Determination at 1491 DIETER STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant 7 and 6-inches variances for three slider replacement bedroom windows measuring 17 high by 27 wide and 18 high by 33 wide and grant a 2-inch variance on the sill height; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.