



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
146

Type: Resolution LH Fire Ordered **Status:** Passed
Windows

In control: City Council

Final action: 10/5/2011

Title: Appeal of Shah Vang to a Fire Certificate of Occupancy Inspection Correction Notice at 1193 COOK AVENUE EAST.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1193 Cook.appeal.8-25-11.pdf, 2. 1193 Cook Ave E.Vang Ltr 10-3-11.pdf

Date	Ver.	Action By	Action	Result
10/11/2011	2	Mayor's Office	Signed	
10/5/2011	2	City Council	Adopted	Pass
9/13/2011	1	Legislative Hearings	Referred	

Appeal of Shah Vang to a Fire Certificate of Occupancy Inspection Correction Notice at 1193 COOK AVENUE EAST.

Egress windows were original and grandfathered. Egress windows were short few inches.

August 18, 2011

Hearing required.

WHEREAS, in the matter of the Appeal of Shah Vang to a Fire Certificate of Occupancy Inspection Correction Notice at 1193 COOK AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance for the double hung window in the south bedroom, deny a variance for the awning window in the north bedroom and the sill height, and grant a 90-day extension to replace the awning window and install a step the width of the window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.