



## Legislation Details (With Text)

**File #:** RLH WP 11- 66 **Version:** 2

**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 10/19/2011

**Title:** Appeal of Mark Mason to an Egress Window Non-Compliance Determination at 1152 ROSE AVENUE EAST.

**Sponsors:** Dan Bostrom

**Indexes:** Ward - 6, Windows

**Code sections:**

**Attachments:** 1. 1152 Rose E.appeal.8-29-11.pdf, 2. 1152 Rose Ave E.Cuts Custom Ltr 9-29-11.pdf

Date	Ver.	Action By	Action	Result
10/21/2011	2	Mayor's Office	Signed	
10/19/2011	2	City Council	Adopted	Pass
9/13/2011	1	Legislative Hearings	Referred	

Appeal of Mark Mason to an Egress Window Non-Compliance Determination at 1152 ROSE AVENUE EAST.

Category 2 building - Replaced two old windows with largest possible w/o opening walls & re-framing. Made windows bigger than before. Also, contractor who is long gone did not do any of this so now I'm picking up the pieces.

August 17, 2011

Yes, window 1: 5 inches in opening height and 1 inch in opening width and window 2: 3 inches in opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of Mark Mason to an Egress Window Non-Compliance Determination at 1152 ROSE AVENUE EAST; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable width and a 5-inch variance on the openable height of one double hung replacement egress bedroom window measuring 19 inches wide by 19 inches high, and grant a 3-inch variance on the openable width of one crank-out replacement egress bedroom window measuring 17 inches wide by 43 inches high; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.