



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
161

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 10/19/2011

**Title:** Appeal of William Perrson to a Fire Certificate of Occupancy Correction Notice at 783 SIXTH STREET EAST.

**Sponsors:** Kathy Lantry

**Indexes:** Ward - 7, Windows

**Code sections:**

**Attachments:** 1. 783 6th.appeal.9-27-11.pdf, 2. 783 Sixth St E.Persson Ltr 9-29-11.pdf

Date	Ver.	Action By	Action	Result
10/21/2011	2	Mayor's Office	Signed	
10/19/2011	2	City Council	Adopted	Pass
9/27/2011	1	Legislative Hearings	Referred	

Appeal of William Perrson to a Fire Certificate of Occupancy Correction Notice at 783 SIXTH STREET EAST.

Clear opening of existing FS 33 x 22-1/4 double hung window.

August 4, 2011

Yes, 2 inches in the egress opening height. No hearing necessary.

WHEREAS, in the matter of the appeal of William Perrson to a Fire Certificate of Occupancy Correction Notice at 783 SIXTH STREET EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the egress window in the first level bedroom in Unit 4; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.