



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
165

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 10/19/2011

Title: Appeal of Rosa E. Arias to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1026 PROSPERITY AVENUE.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 1026 Prosperity.appeal.9-19-11.pdf

Date	Ver.	Action By	Action	Result
10/21/2011	2	Mayor's Office	Signed	
10/19/2011	2	City Council	Adopted	Pass
9/27/2011	1	Legislative Hearings	Referred	

Appeal of Rosa E. Arias to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1026 PROSPERITY AVENUE.

Only egress windows

September 13, 2011

Yes, for bedrooms on the southwest and southeast sides. Hearing on the basement windows.

WHEREAS, in the matter of the appeal of Rosa E. Arias to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 1026 PROSPERITY AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in the southwest and southeast side bedrooms, and deny the appeal on the basement egress bedroom window and still height issues; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.