



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
155

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 10/19/2011

Title: Appeal of Tony Swanson to a Fire Certificate of Occupancy Correction Notice at 921 JESSIE STREET.

Sponsors: Lee Helgen

Indexes: Ward - 5, Windows

Code sections:

Attachments: 1. 921 Jessie.appeal.9-20-11.pdf

Date	Ver.	Action By	Action	Result
10/21/2011	2	Mayor's Office	Signed	
10/19/2011	2	City Council	Adopted	Pass
9/20/2011	1	Legislative Hearings	Referred	

Appeal of Tony Swanson to a Fire Certificate of Occupancy Correction Notice at 921 JESSIE STREET.

#3 Interior - MSFC 1026.1 request variance on openable height.

August 18, 2011

Yes, 4 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the appeal of Tony Swanson to a Fire Certificate of Occupancy Correction Notice at 921 JESSIE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress windows in all three bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.