



Legislation Details (With Text)

File #: RLH WP 11- 63 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 10/19/2011
Title: Appeal of Ker Moua to an Egress Window Non-Compliance Determination at 922 WILSON AVENUE.
Sponsors: Kathy Lantry
Indexes: Ward - 7, Windows
Code sections:
Attachments: 1. 922 Wilson.appeal.8-25-11.pdf, 2. 922 Wilson Ave.Moua Ltr 9-13-11.pdf

Date	Ver.	Action By	Action	Result
10/21/2011	2	Mayor's Office	Signed	
10/19/2011	2	City Council	Adopted	Pass
9/13/2011	1	Legislative Hearings	Referred	

Appeal of Ker Moua to an Egress Window Non-Compliance Determination at 922 WILSON AVENUE.

The window did not pass bulding inspection for sleeping room. [sic]

August 24, 2011

Yes, 4 inches in the egress opening width. No hearing necessary

WHEREAS, in the matter of Appeal of Ker Moua to an Egress Window Non-Compliance Determination at 922 WILSON AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable width of one casement replacement egress bedroom window measuring 43 inches high by 16.25 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.