



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FCO 11- 333 **Version:** 2
Type: Resolution LH Fire C of O OR Correction Order **Status:** Passed
In control: City Council
Final action: 10/19/2011
Title: Appeal of Xiong Pao Chang to a Fire Certificate of Occupancy Correction Notice at 933 WHITE BEAR AVENUE NORTH.
Sponsors: Dan Bostrom
Indexes: Fire C of O Letter, Ward - 6
Code sections:
Attachments: 1. 933 White Bear.appeal.8-19-11.pdf, 2. 933 White Bear Ave N.Photos.9-27-11.pdf

| Date | Ver. | Action By | Action | Result |
|------------|------|----------------------|----------|--------|
| 10/21/2011 | 2 | Mayor's Office | Signed | |
| 10/19/2011 | 2 | City Council | Adopted | Pass |
| 9/20/2011 | 1 | Legislative Hearings | Referred | |
| 9/6/2011 | 1 | Legislative Hearings | | |

Appeal of Xiong Pao Chang to a Fire Certificate of Occupancy Correction Notice at 933 WHITE BEAR AVENUE NORTH.

Number 9 and 10 of attached correction notice.

July 21, 2011

WHEREAS, in the matter of the appeal of Xiong Pao Chang to a Fire Certificate of Occupancy Correction Notice at 933 WHITE BEAR AVENUE NORTH, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal for the fire rated floor and/or ceiling issue in Items 6 and 9, grant a 2-inch variance on the openable height of the egress window in all residential units; and grant a variance on the sill height on the condition that appellant install a step; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.