



## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
175

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 10/19/2011

**Title:** Appeal of Rev. Howard Googins to a Fire Certificate of Occupancy Inspection Correction Notice at 830 PORTLAND AVENUE.

**Sponsors:** Melvin Carter III

**Indexes:** Fire C of O Letter, Ward - 1, Windows

**Code sections:**

**Attachments:** 1. 830 Portland.appeal.9-23-11.pdf, 2. 830 Portland Ave.Googin Ltr.pdf

Date	Ver.	Action By	Action	Result
10/21/2011	2	Mayor's Office	Signed	
10/19/2011	2	City Council	Adopted	Pass
10/4/2011	1	Legislative Hearings	Referred	

Appeal of Rev. Howard Googins to a Fire Certificate of Occupancy Inspection Correction Notice at 830 PORTLAND AVENUE.

Only egress windows

August 30, 2011

Yes, up to a 6 inch variance in egress window opening heights. No hearing necessary.

WHEREAS, in the matter of the Appeal of Rev. Howard Googins to a Fire Certificate of Occupancy Inspection Correction Notice at 830 PORTLAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable height of the northwest bedroom egress window; grant a 6-inch variance on the openable height of the southwest bedroom egress window; and grant a 1.5-inch variance on the openable height of the southwest bedroom egress window; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.