



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
187

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 11/2/2011

Title: Appeal of Earl F. Miller to a Fire Certificate of Occupancy Correction Notice at 1116 PACIFIC STREET.

Sponsors: Kathy Lantry

Indexes: Ward - 7, Windows

Code sections:

Attachments: 1. 1116 Pacific.appeal.10-04-11.pdf, 2. 1116 Pacific St.Miller Ltr 10-13-11.pdf

Date	Ver.	Action By	Action	Result
11/9/2011	2	Mayor's Office	Signed	
11/2/2011	2	City Council	Adopted	Pass
10/11/2011	1	Legislative Hearings	Referred	

Appeal of Earl F. Miller to a Fire Certificate of Occupancy Correction Notice at 1116 PACIFIC STREET.

Egress Windows

September 21, 2011

Yes, upper floor east bedroom 4 inches in egress opening height, upper floor north bedroom 1 inch in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Earl F. Miller to a Fire Certificate of Occupancy Correction Notice at 1116 PACIFIC STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inch variance on the openable height of the egress window in the upper floor east bedroom and a 1-inch variance on the openable height of the egress window in the upper floor north bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.