



## Legislation Details (With Text)

**File #:** RLH WP 11- 87 **Version:** 2  
**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 11/16/2011  
**Title:** Appeal of Renewal by Andersen to two Egress Window Non-Compliance Determinations at 2053 IOWA AVENUE EAST.  
**Sponsors:** Dan Bostrom  
**Indexes:** Ward - 6, Windows  
**Code sections:**  
**Attachments:** 1. 2053 Iowa.appeal.10-7-11.pdf, 2. 2053 Iowa Ave E.Renewal by Andersen Ltr 10-13-11.pdf, 3. 2053 Iowa Ave E.Renewal by Andersen Revised Ltr 10-13-11.pdf

Date	Ver.	Action By	Action	Result
11/22/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/18/2011	1	Legislative Hearings	Referred	

Appeal of Renewal by Andersen to two Egress Window Non-Compliance Determinations at 2053 IOWA AVENUE EAST.

We are appealing 3 replacement windows that will not comply w/egress policy. Openable height will be short by 5". Width & glazed area criteria is met/exceeded. Specific sizes attached. Please approve.

October 3, 2011 (both)

WHEREAS, in the matter of the Appeal of Renewal by Andersen to two Egress Window Non-Compliance Determinations at 2053 IOWA AVENUE EAST; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of two double hung replacement egress bedroom windows measuring 19 inches high by 36 inches wide, and grant a 5-inch variance on the openable height of one double hung replacement egress bedroom window measuring 19 inches high by 28 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.