



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
194

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 11/16/2011

Title: Appeal of Michael J. Mazzara to a Deficiency List for Fire Certificate of Occupancy Inspection at 1076 CONWAY STREET.

Sponsors: Kathy Lantry

Indexes: Fire C of O Letter, Ward - 7, Windows

Code sections:

Attachments: 1. 1076 Conway.appeal.10-7-11.pdf, 2. 1076 Conway St.Mazzarra Ltr 10-20-11.pdf

Date	Ver.	Action By	Action	Result
11/23/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/18/2011	1	Legislative Hearings	Referred	

Appeal of Michael J. Mazzara to a Deficiency List for Fire Certificate of Occupancy Inspection at 1076 CONWAY STREET.

Only egress windows - Height variance of 1", 23" height where 24" is required

October 10, 2011

WHEREAS, in the matter of Appeal of Michael J. Mazzara to a Deficiency List for Fire Certificate of Occupancy Inspection at 1076 CONWAY STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable height of the egress window in the upper unit northwest bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.