



## Legislation Details (With Text)

**File #:** RLH FOW 11- **Version:** 2  
201

**Type:** Resolution LH Fire Ordered Windows **Status:** Passed

**In control:** City Council

**Final action:** 11/16/2011

**Title:** Appeal of Charles Nosie to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 970 CONWAY STREET.

**Sponsors:** Kathy Lantry

**Indexes:** Fire C of O Letter, Ward - 7, Windows

**Code sections:**

**Attachments:** 1. 970 Conway.appeal.10-12-11.pdf, 2. 970 Conway.Photos.7-27-11.pdf, 3. 970 Conway St.Nosie Ltr 10-20-11.pdf

Date	Ver.	Action By	Action	Result
11/23/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/18/2011	1	Legislative Hearings	Referred	

Appeal of Charles Nosie to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 970 CONWAY STREET.

Only egress windows

October 7, 2011

Yes, 1 inch variance in egress opening height, and 2 inches in egress opening width. No hearing necessary.

WHEREAS, in the matter of Appeal of Charles Nosie to a Re-Inspection Fire Certificate of Occupancy With Deficiencies at 970 CONWAY STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a .5-inch variance on the openable height and 1.5-inch variance on the openable width of the egress window in the upper floor west bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.