



Legislation Details (With Text)

File #: RLH FOW 11- Version: 2
181

Type: Resolution LH Fire Ordered Windows

Status: Passed

In control: City Council

Final action: 11/16/2011

Title: Appeal of Gretchen Iwen to a Fire Certificate of Occupancy Inspection Correction Notice at 1899 BEECHWOOD AVENUE.

Sponsors: Pat Harris

Indexes: Fire C of O Letter, Ward - 3, Windows

Code sections:

Attachments: 1. 1899 Beechwood.appeal.9-28-11.pdf, 2. 1899 Beechwood Ave.Iwen Ltr 10-20-11.pdf

Date	Ver.	Action By	Action	Result
11/23/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/18/2011	1	Legislative Hearings	Referred	

Appeal of Gretchen Iwen to a Fire Certificate of Occupancy Inspection Correction Notice at 1899 BEECHWOOD AVENUE.

Double hung windows are 1.5/1 inch short of what they are suppose to be.

September 16, 2011

Yes, 2 inches in egress window opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Gretchen Iwen to a Fire Certificate of Occupancy Inspection Correction Notice at 1899 BEECHWOOD AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1.5-inch variance on the openable height of the egress window in the north bedroom and grant a 1-inch variance on the openable height of the egress window in the south bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.