



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
221

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 11/16/2011

Title: Appeal of Daniel Schmidt, Saint Paul Ramsey County Department of Public Health, to an Egress Window Non-Compliance Determination at 240 WYOMING STREET EAST.

Sponsors: Dave Thune

Indexes: Fire C of O Letter, Ward - 2

Code sections:

Attachments: 1. 240 Wyoming.appeal.10-20-11.pdf

Date	Ver.	Action By	Action	Result
11/22/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
11/1/2011	1	Legislative Hearings	Referred	

Appeal of Daniel Schmidt, Saint Paul Ramsey County Department of Public Health, to an Egress Window Non-Compliance Determination at 240 WYOMING STREET EAST.

(2 egress windows)

October 20, 2011

RC Public Health.

Yes, 5 inch variance in egress opening height.

WHEREAS, in the matter of the Appeal of Daniel Schmidt, Saint Paul Ramsey County Department of Public Health, to an Egress Window Non-Compliance Determination at 240 WYOMING STREET EAST; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of two double hung wood acraft replacement egress bedroom windows measuring 19-3/4 inches high by 22.5 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.