City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

City of Saint Paul

Legislation Details (With Text)

File #:	RLH WP 11-95 **Version:** 2		
Type:	Resolution LH Window Permit	**Status:**	Passed
		In control:	City Council
		Final action:	11/16/2011
Title:	Appeal of Mark J. Pierce, MP Systems Inc., to an Egress Window Non-Compliance Determination at 1338 REANEY AVENUE EAST.		
Sponsors:	Kathy Lantry		
Indexes:	Ward - 7, Windows		
Code sections:			
Attachments:	1. 1338 Reaney.appeal.10-12-11.pdf, 2. 1338 Reaney Aven.MP Systems Inc Ltr 10-25-11.pdf		

Date	Ver.	Action By	Action	Result
11/22/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/25/2011	1	Legislative Hearings	Referred	

Appeal of Mark J. Pierce, MP Systems Inc., to an Egress Window Non-Compliance Determination at 1338 REANEY AVENUE EAST.

Two windows in home due to size and permit issue.

Yes, 1 inch in egress opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of Mark J. Pierce, MP Systems Inc., to an Egress Window Non-Compliance Determination at 1338 REANEY AVENUE EAST, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 1-inch variance on the openable width of two casement replacement egress bedroom windows measuring at 55 inches high by 19 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.

powered by Legistar™