



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
218

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 11/16/2011

Title: Appeal of Daniel R. Fowlds to a Fire Certificate of Occupancy Correction Notice at 2007 PORTLAND AVENUE.

Sponsors: Russ Stark

Indexes: Fire C of O Letter, Ward - 4, Windows

Code sections:

Attachments: 1. 2007 Portland.appeal.10-19-11.pdf

Date	Ver.	Action By	Action	Result
11/22/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
11/1/2011	1	Legislative Hearings	Referred	

Appeal of Daniel R. Fowlds to a Fire Certificate of Occupancy Correction Notice at 2007 PORTLAND AVENUE.

Egress Windows

October 12, 2011

Yes, 4 inches egress opening width for upper unit front bedroom. No hearing necessary.

WHEREAS, in the matter of the Appeal of Daniel R. Fowlds to a Fire Certificate of Occupancy Correction Notice at 2007 PORTLAND AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 4-inches egress opening width for the upper unit front bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.