



Legislation Details (With Text)

File #: RLH WP 11- 91 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 11/16/2011
Title: Appeal of St. Paul-Ramsey County Department of Public Health to two Egress Window Non-Compliance Determinations at 674 MAGNOLIA AVENUE EAST.
Sponsors: Dan Bostrom
Indexes: Ward - 6, Windows
Code sections:
Attachments: 1. 674 Magnolia.appeal.10-13-11.pdf, 2. 674 Magnolia Ave.Public Health.Ltr 10-25-11.pdf

Date	Ver.	Action By	Action	Result
11/22/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/25/2011	1	Legislative Hearings	Referred	

Appeal of St. Paul-Ramsey County Department of Public Health to two Egress Window Non-Compliance Determinations at 674 MAGNOLIA AVENUE EAST.

Only egress windows

October 13, 2011 (both)

Yes, 1 inch in egress opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of St. Paul-Ramsey County Department of Public Health to two Egress Window Non-Compliance Determinations at 674 MAGNOLIA AVENUE EAST; the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant;

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant grant a 1-inch variance on the openable width of one double hung vinyl replacement egress bedroom window measuring 25.9 inches high by 19.2 inches wide and grant a 2-inch variance on the openable height of one double replacement egress bedroom window measuring 22 inches high by 23.2 inches wide; No, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.