



Legislation Details (With Text)

File #: RLH FOW 11- **Version:** 2
198

Type: Resolution LH Fire Ordered Windows **Status:** Passed

In control: City Council

Final action: 11/16/2011

Title: Appeal of Relando Aguilar to a Fire Certificate of Occupancy Correction Notice at 833 YORK AVENUE.

Sponsors: Dan Bostrom

Indexes: Fire C of O Letter, Ward - 6, Windows

Code sections:

Attachments: 1. 833 York.appeal.10-11-11.pdf, 2. 833 York Ave.Aguilar Ltr 10-20-11.pdf

Date	Ver.	Action By	Action	Result
11/23/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/18/2011	1	Legislative Hearings	Referred	

Appeal of Relando Aguilar to a Fire Certificate of Occupancy Correction Notice at 833 YORK AVENUE.

None listed

September 26, 2011

Yes, 4 inches in egress opening height. No hearing necessary.

WHEREAS, in the matter of the Appeal of Relando Aguilar to a Fire Certificate of Occupancy Correction Notice at 833 YORK AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 3.5 inch variance on the openable height of the egress window in the south bedroom of Unit 2; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.