



## Legislation Details (With Text)

**File #:** RLH WP 11- 93 **Version:** 2

**Type:** Resolution LH Window Permit **Status:** Passed  
**In control:** City Council  
**Final action:** 11/16/2011

**Title:** Appeal of Larry Columbus, Columbus Exteriors, to an Egress Window Non-Compliance Determination at 570 IGLEHART AVENUE.

**Sponsors:** Melvin Carter III

**Indexes:** Ward - 1, Windows

**Code sections:**

**Attachments:** 1. 570 Iglehart.appeal.10-25-11.pdf, 2. 570 Iglehart Ave.Ltr 10-25-11.pdf

Date	Ver.	Action By	Action	Result
11/22/2011	2	Mayor's Office	Signed	
11/16/2011	2	City Council	Adopted	Pass
10/25/2011	1	Legislative Hearings	Referred	

Appeal of Larry Columbus, Columbus Exteriors, to an Egress Window Non-Compliance Determination at 570 IGLEHART AVENUE.

Egress window non-compliance

August 17, 2011

Yes, 2 inches in egress opening width. No hearing necessary.

WHEREAS, in the matter of the Appeal of Larry Columbus, Columbus Exteriors, to an Egress Window Non-Compliance Determination at 570 IGLEHART AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 2-inch variance on the openable width of five double hung replacement egress bedroom windows measuring 42 inches high by 18 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.