



Legislation Details (With Text)

File #: RLH WP 11- 99 **Version:** 2
Type: Resolution LH Window Permit **Status:** Passed
In control: City Council
Final action: 12/7/2011
Title: Appeal of Michael Sellers to an Egress Window Non-Compliance Determination at 798 LAKE STREET.
Sponsors: Kathy Lantry
Indexes: Ward - 7, Windows
Code sections:
Attachments: 1. 798 Lake.appeal.10-25-11.pdf, 2. 798 Lake St.Sellers Ltr 11-8-11.pdf

Date	Ver.	Action By	Action	Result
12/13/2011	2	Mayor's Office	Signed	
12/7/2011	2	City Council	Adopted	Pass
11/8/2011	1	Legislative Hearings	Referred	

Appeal of Michael Sellers to an Egress Window Non-Compliance Determination at 798 LAKE STREET.

Appealing the egress window 21" high and 36" wide.

October 25, 2011

None listed on non-compliance determination. Fire C of O inspector James Thomas.

Not sure why both a non-compliance determination and fire orders are attached. It looks like the windows got called out in fire orders because the opening dimensions were In both the measurements in question were for an egress opening of 19"Hx23"W. The non-compliance determination showed dimensions of 36"Hx21" width - so this needs no variance.

Yes, 5 inches in egress opening height (as listed in Fire C of O orders. No hearing necessary. Let's call appellant right away and indicate window replacement is not necessary.

WHEREAS, in the matter of the Appeal of Michael Sellers to an Egress Window Non-Compliance Determination at 798 LAKE STREET, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of the egress windows in all bedrooms; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.