



# City of Saint Paul

City Hall and Court House  
15 West Kellogg Boulevard  
Phone: 651-266-8560

## Legislation Text

---

**File #:** RLH FCO 11-256, **Version:** 2

---

Appeal of Margaret Uriah to a Fire Certificate of Occupancy Reinspection at 624 JAMES AVENUE.

Upper unit bedroom window measures 14.5" high by 28" wide openable space; 6.5 sq. ft. of glazed glass

June 17, 2011

WHEREAS, in the matter of the appeal of Margaret Uriah to a Fire Certificate of Occupancy Reinspection at 624 JAMES AVENUE, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council deny the appeal and grant an extension for 90 days to come into compliance on the window in the upper unit, southeast bedroom; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.