



City of Saint Paul

City Hall and Court House
15 West Kellogg Boulevard
Phone: 651-266-8560

Legislation Text

File #: RLH WP 11-50, **Version:** 2

Appeal of Derek Tanbeg for The Window Store Home Improvement, on behalf of John Goolshy, to an Egress Window Non-Compliance Determination at 607 ALDINE STREET.

Nothing indicated

July 21, 2011

Yes, 5 inches in height of egress opening.

WHEREAS, in the matter of the appeal of Derek Tanbeg for The Window Store Home Improvement, on behalf of John Goolshy, to an Egress Window Non-Compliance Determination at 607 Aldine Street, the Legislative Hearing Officer has reviewed the appeal and considered the testimony of City staff and the appellant; and

WHEREAS, the Legislative Hearing Officer recommends that the City Council grant a 5-inch variance on the openable height of one double hung replacement egress window measuring 19.93 inches high by 29.34 inches wide; Now, Therefore, Be It

RESOLVED, that the Saint Paul City Council hereby accepts and adopts the Legislative Hearing Officer's recommendation in this matter.